- 4. A level manoeuvring space of 1500 mm x 1500 mm must connect to each wheelchair space.
- 5. It shall be marked with the international symbol of access (ISA), whether as permanent seating spaces or removable seating areas.
- 6. Both the surface of wheelchair spaces and the clear manoeuvring space are level having a maximum longitudinal gradient of 1%.
- 7. For facilities with fixed seats, designated wheelchair spaces shall be arranged into groups of 2. Each group of wheelchair spaces must have at least an equal number of fixed seats.
- 8. If the designated wheelchair spaces include removable or foldable seats, the conversion process shall be quick and easy.
- 9. Wheelchair spaces shall be provided in all auditorium-seating sections.
- 10. The number of reserved wheelchair spaces shall comply: 1 reserved wheelchair space for every 50 seats or fraction thereof and beyond 500 seats, 1 more for every 100 seats or fraction thereof.
- 11. In theatres, cinemas, conference rooms, auditoriums and all the facilities where people are expected to sit or wait, it is recommended that some seats should have a space for service animals near the owner.
- 12. A space at the front of the hall or room where a sign language interpreter can be easily seen shall have an independent overhead light.
- 13. A sufficient number of designated accessible seats for people with hearing impairments should be provided in front of the sign language interpreter.
- 14. Aisle seats and its adjacent shall have foldable armrests.