

2.2.10 Fabrication

- A. Shop assembled casework for delivery to site in units easily handled and to permit passage through building openings.
- B. Fit shelves, doors, and exposed edges with 9.5 mm matching hardwood matching veneer/plastic/aluminium edging. Use one piece for full length only.
- C. Cap exposed plastic laminate finish edges with material of same finish and pattern. Or plastic trim or aluminium trims.
- D. Door and Drawer Fronts: 19 mm thick; flush style.
- E. When necessary to cut and fit on site, provide materials with ample allowance for cutting. Provide trim for scribing and site cutting.
- F. Apply plastic laminate finish in full uninterrupted sheets consistent with manufactured sizes. Fit corners and joints hairline; secure with concealed fasteners. Slightly bevel arises. Locate counter butt joints minimum 600 mm from sink cut-outs.

2.2.11 Site Finishing

Not Used

2.3 Part 3 Execution

2.3.1 Examination

- A. Section 01039 - Coordination and Meetings: Verification of existing conditions before starting work.
- B. Verify adequacy of backing and support framing.
- C. Verify location and sizes of utility rough-in associated with work of this section.

2.3.2 Installation

- A. Set and secure casework in place; rigid, plumb, and level.
- B. Use fixture attachments in concealed locations for wall mounted components.
- C. Use concealed joint fasteners to align and secure adjoining cabinet units and counter tops.