

Table 5.36 — Educational premises – Educational buildings

Ref. no.	Type of area, task or activity	E_m lx	UGR_L —	U_o —	R_a —	Specific requirements
5.36.1	Classrooms, tutorial rooms	300	19	0,60	80	Lighting should be controllable.
5.36.2	Classroom for evening classes and adults education	500	19	0,60	80	Lighting should be controllable.
5.36.3	Auditorium, lecture halls	500	19	0,60	80	Lighting should be controllable to accommodate various A/V needs.
5.36.4	Black, green and white boards	500	19	0,70	80	Specular reflections shall be prevented. Presenter/teacher shall be illuminated with suitable vertical illuminance.
5.36.5	Demonstration table	500	19	0,70	80	In lecture halls 750 lx.
5.36.6	Art rooms	500	19	0,60	80	
5.36.7	Art rooms in art schools	750	19	0,70	90	5 000 K < T_{CP} 6 500 K.
5.36.8	Technical drawing rooms	750	16	0,70	80	
5.36.9	Practical rooms and laboratories	500	19	0,60	80	
5.36.10	Handicraft rooms	500	19	0,60	80	
5.36.11	Teaching workshop	500	19	0,60	80	
5.36.12	Music practice rooms	300	19	0,60	80	
5.36.13	Computer practice rooms (menu driven)	300	19	0,60	80	DSE-work, see 4.9.
5.36.14	Language laboratory	300	19	0,60	80	
5.36.15	Preparation rooms and workshops	500	22	0,60	80	
5.36.16	Entrance halls	200	22	0,40	80	
5.36.17	Circulation areas, corridors	100	25	0,40	80	