CODE

COMMENTARY

of higher grades, these limits are replaced by the expressions $\varepsilon_{ty} + 0.003$ and $\varepsilon_{ty} + 0.008$, respectively. The first expression is the same expression as used for the limit on ε_t for classification of tension-controlled members in Table 21.2.2; this expression is further described in Commentary R21.2.2. The second expression provides a limit on ε_t with Grade 420 reinforcement that is approximately the same value as the former constant of 0.010.

Table 8.4.2.2.4—Maximum modified values of γ_f for nonprestressed two-way slabs

Column location	Span direction	v_{uv}	ε_t (within b_{slab})	Maximum modified γ_f
Corner column	Either direction	$\le 0.5\phi v_c$	$\ge \varepsilon_{ty} + 0.003$	1.0
Edge column	Perpendicular to the edge	$\le 0.75\phi v_c$	$\ge \varepsilon_{ty} + 0.003$	1.0
	Parallel to the edge	$\le 0.4\phi v_c$	$\ge \varepsilon_{ty} + 0.008$	$\dfrac{1.25}{1+\left(\frac{2}{3}\right)\sqrt{\frac{b_1}{b_2}}} \le 1.0$
Interior column	Either direction	$\le 0.4\phi v_c$	$\ge \varepsilon_{ty} + 0.008$	$\dfrac{1.25}{1+\left(\frac{2}{3}\right)\sqrt{\frac{b_1}{b_2}}} \le 1.0$

8.4.2.2.5 Concentration of reinforcement over the column by closer spacing or additional reinforcement shall be used to resist moment on the effective slab width defined in 8.4.2.2.2 and 8.4.2.2.3.

8.4.2.2.6 The fraction of M_{sc} not calculated to be resisted by flexure shall be assumed to be resisted by eccentricity of shear in accordance with 8.4.4.2.

8.4.3 *Factored one-way shear*

8.4.3.1 For slabs built integrally with supports, V_u at the support shall be permitted to be calculated at the face of support.

8.4.3.2 Sections between the face of support and a critical section located d from the face of support for nonprestressed slabs and $h/2$ from the face of support for prestressed slabs shall be permitted to be designed for V_u at that critical section if (a) through (c) are satisfied:

(a) Support reaction, in direction of applied shear, introduces compression into the end regions of the slab.
(b) Loads are applied at or near the top surface of the slab.
(c) No concentrated load occurs between the face of support and critical section.

8.4.4 *Factored two-way shear*

R8.4.4 *Factored two-way shear*

The calculated shear stresses in the slab around the column are required to conform to the requirements of 22.6.