CODE

(d) 300 mm

18.4.2.5 Transverse reinforcement spacing shall not exceed ***d*/2** throughout the length of the beam.

18.4.2.6 In beams having factored axial compressive force exceeding $A_g f_c'/10$, transverse reinforcement required by 18.4.2.5 shall conform to 25.7.2.2 and either 25.7.2.3 or 25.7.2.4.

COMMENTARY

in 18.4.2.6 are intended to provide lateral support for beam longitudinal reinforcement.



***Fig. R18.4.2**—Design shears for intermediate moment frames.*

18.4.3 *Columns*

18.4.3.1 ϕV_n shall be at least the lesser of (a) and (b):

(a) The shear associated with development of nominal moment strengths of the column at each restrained end of

R18.4.3 *Columns*

According to 18.4.3.1(a), the factored shear force is determined from a free-body diagram obtained by cutting through the column ends, with end moments assumed equal to the nominal moment strengths acting in reverse curva-