

2. Serial number of the ticket
 3. Date
 4. Name of purchaser
 5. Project designation
 6. Class or designation of concrete
 7. Weights and quantities of each concrete ingredient
 8. Time of loading
 9. Time of departure
 10. Amount of concrete batched
 11. Type and amount of admixture
 12. Slump at plant and site
 13. Proposed concrete strength
 14. Vehicle number
 15. Driver's name
 16. Concrete Temperature at plant and site
 17. Time of adding water for the first time in the mix.
- F. The Ready-mix plant must be equipped with separate automatic dosing dispensers for each type of admixture, and feeds a fixed quantity of additive into the mixing water before the water is discharged into the mix
- G. The batching plant shall comply with the following tolerance limits for ready-mixed concrete ingredients:

Table 3-1: Tolerance limits for ready-mix concrete ingredients

No	Ingredients	Individual Batch (%)	Load Cumulative (%)
1	Coarse aggregate (20mm)	±2	±1
2	Coarse aggregate (10mm)	±2	±1
3	Fine aggregate (5mm)	±2	±1
4	Dune Sand	±2	±1
5	Cement	±2	±1
6	Water	±1	±1
7	Ice	±1	±1
8	Liquid Admixture(s)	±3	±3

- H. Plant must be equipped with a sufficient capacity water chillier capable of