

- 7.2. Exposed bottom edge less than 18 inches (457 mm) above the floor;
- 7.3. Exposed top edge greater than 36 inches (914 mm) above the floor; and
- 7.4. One or more walking surface(s) within 36 inches (914 mm) horizontally of the plane of the glazing.

Exception: Safety glazing for Item 7 is not required for the following installations:

- 1. A protective bar 1½ inches (38 mm) or more in height, capable of withstanding a horizontal load of 50 plf (730 N/m) without contacting the glass, is installed on the accessible sides of the glazing 34 inches to 38 inches (864 mm to 965 mm) above the floor.
- 2. The outboard pane in insulating glass units or multiple glazing where the bottom exposed edge of the glass is 25 feet (7620 mm) or more above any grade, roof, walking surface or other horizontal or sloped [within 45 degrees (0.78 rad) of horizontal] surface adjacent to the glass exterior.
- 8. Glazing in *guards* and railings, including structural baluster panels and nonstructural in-fill panels, regardless of area or height above a walking surface.
- 9. Glazing in walls and fences enclosing indoor and outdoor swimming pools, hot tubs and spas where all of the following conditions are present:
 - 9.1. The bottom edge of the glazing on the pool or spa side is less than 60 inches (1524 mm) above a walking surface on the pool or spa side of the glazing; and
 - 9.2. The glazing is within 60 inches (1524 mm) horizontally of the water's edge of a swimming pool or spa.
- 10. Glazing adjacent to *stairways*, landings and ramps within 36 inches (914 mm) horizontally of a walking surface; when the exposed surface of the glass is less than 60 inches (1524 mm) above the plane of the adjacent walking surface.
- 11. Glazing adjacent to *stairways* within 60 inches (1524 mm) horizontally of the bottom tread of a *stairway* in any direction when the exposed surface of the glass is less than 60 inches (1524 mm) above the nose of the tread.

Exception: Safety glazing for Item 10 or 11 is not required for the following installations where:

- 1. The side of a *stairway*, landing or ramp which has a *guard* or handrail, including balusters or in-fill panels, complying with the provisions of Sections 1013 and 1607.7; and
- 2. The plane of the glass is greater than 18 inches (457 mm) from the railing.

2406.4.1 Exceptions. The following products, materials and uses shall not be considered specific hazardous locations:

- 1. Openings in doors through which a 3-inch (76 mm) sphere is unable to pass.
- 2. Decorative glass in Section 2406.4, Item 1, 6 or 7.
- 3. Glazing materials used as curved glazed panels in revolving doors.
- 4. Commercial refrigerated cabinet glazed doors.
- 5. Glass-block panels complying with Section 2101.2.5.
- 6. Louvered windows and jalousies complying with the requirements of Section 2403.5.
- 7. Mirrors and other glass panels mounted or hung on a surface that provides a continuous backing support.