

3412.6.13 Maximum Exit Access Travel Distance	***		
3412.6.14 Elevator Control			
3412.6.15 Means of Egress Emergency Lighting	***		
3412.6.16 Mixed Occupancies		***	
3412.6.17 Automatic Sprinklers		$\div 2 =$	
3412.6.18 Standpipes			
3412.6.19 Incidental Accessory Occupancy			
Building score - total value			

***No applicable value to be inserted.

3412.8 Safety scores. The values in Table 3412.8 are the required mandatory safety scores for the evaluation process *listed* in Section 3412.6.

TABLE 3412.8 MANDATORY SAFETY SCORES^a

OCCUPANCY	FIRE SAFETY (MFS)	MEANS OF EGRESS (MME)	GENERAL SAFETY (MGS)
A-1	16	27	27
A-2	19	30	30
A-3	18	29	29
A-4, E	23	34	34
B	24	34	34
F	20	30	30
M	19	36	36
R	17	34	34
S-1	15	25	25
S-2	23	33	33

a. MFS = Mandatory Fire Safety;

MME = Mandatory Means of Egress;

MGS = Mandatory General Safety.