

- e. Manufacturers technical data.
- f. Storage instructions.
- g. Raw material certificates
- h. Connection details
- i. Load tables (if applicable)
- j. Installation instructions.

B. Shop Drawings

- 1. Shop drawings for all GRP products shall be submitted to the Engineer for approval in accordance with the requirements of Section 01300.
- 2. Indicate detail fabrication and erection of each GRP fabrication.
 - a. Include plans, elevations, sections and details of GRP fabrications and their connections.
 - b. Show anchorage and accessory items.

C. Samples

- 1. Samples of each proposed type of GRP product shall be submitted, unless otherwise approved by the Engineer.

D. Method Statements

- 1. Method statements complying with Section 01400 shall be submitted for the following:
 - a. General fabrication methods.
 - b. On-site repairs.
 - c. Panel Tank installation.

3.1.6 Quality Assurance

- A. Products covered by these specifications shall be furnished by a reputable and qualified manufacturer of proven ability who has regularly engaged in the manufacture and installation of GRP systems for at least five years.
- B. Prior to dispatch from the factory, the Contractor shall notify the Engineer, in sufficient time to allow the Engineer or his representatives to inspect and test the products, if so desired.