

Curb Ramps and Prohibition of accessible path alteration

Facility/Building

Space/Floor

Sheet Number

YES

N/A

NON

Observations

Running gradient $\leq 8\%$				
Width = pedestrian crossing width ≥ 2000 mm				
Present a warning tactile pavement at 300 mm from the edge				
Curb ramp edge level of the road				
Colour and texture = accessible path				
Pendulum Test Value (PTV) ≥ 45				
Cross steep gradient $\leq 2\%$				
Not invading accessible path				
If there is a step in its lateral edge, it is protected by urban furniture				
Curb ramps are aligned				

Prohibition of accessible path alteration

No modification of accessible path for parking entrances				
Parking doors don't obstruct an accessible path				