

Table 5.37 — Health care premises – Rooms for general use

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
						Too high luminances in the patients' visual field shall be prevented.
5.37.1	Waiting rooms	200	22	0,40	80	
5.37.2	Corridors: during the day	100	22	0,40	80	Illuminance at floor level.
5.37.3	Corridors: cleaning	100	22	0,40	80	Illuminance at floor level.
5.37.4	Corridors: during the night	50	22	0,40	80	Illuminance at floor level.
5.37.5	Corridors with multi-purpose use	200	22	0,60	80	Illuminance at task/activity level.
5.37.6	Day rooms	200	22	0,60	80	
5.37.7	Elevators, lifts for persons and visitors	100	22	0,60	80	Illuminance at floor level.
5.37.8	Service lifts	200	22	0,60	80	Illuminance at floor level.

Table 5.38 — Health care premises – Staff rooms

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
5.38.1	Staff office	500	19	0,60	80	
5.38.2	Staff rooms	300	19	0,60	80	