

Internal corridors, alarms and means of egress, gender equality, storage facilities and lockers, accessible dressing and changing rooms, first aid facilities and balconies

Facility/Building		Sheet Number
Space/Floor		

YES N/A NON Observations

Internal corridor

Width \geq 1000 mm				
In direction changes a manoeuvring space of 1200 mm				
Tactile warning surface in any change of level				
Illumination \geq 60 lux				

Alarms and means of egress

Audio and visual emergency alarms				
Visual emergency alarm with 30 flashes per second				
Accessible means of egress marked with accessible signage				

Gender equality

In case of segregated use by gender, same level of accessibility for both genders				
---	--	--	--	--

Storage facilities and lockers

20% of shelves or lockers are in a reaching height distance between 600 - 1200 mm				
---	--	--	--	--