

4 FIRE EXTINGUISHERS, CABINET & ACCESSORIES (SECTION 10522)

4.1 Part 1 General

4.1.1 References

BS 5274 - Fire hose reels (water) for fixed installations.

BS 5423 - Portable fire extinguishers.

NFPA 10 - Portable Fire Extinguishers.

UL 8 - Foam Fire Extinguishers.

UL 92 - Fire Extinguisher and Booster Hose.

UL 154 - Carbon Dioxide Fire Extinguishers.

UL 299 - Dry Chemical Fire Extinguishers.

UL 626 - 2 1/2 Gallon Stored Pressure, Water Type Fire Extinguishers.

UL 711 - Rating and Fire Testing of Fire Extinguishers.

UL 1093 - Halogenated Agent Fire Extinguishers.

4.1.2 Performance Requirements

- A. Conform to NFPA 10 applicable code.
- B. Provide extinguishers classified and labelled by testing firm acceptable to the Engineer for the purpose specified and indicated.

4.1.3 Submittals for Review

- A. Section 01300 - Submittals: Procedures for submittals.
- B. Shop Drawings: Indicate cabinet physical dimensions, rough-in measurements for recessed cabinets, wall bracket mounted measurements and location.
- C. Product Data: Provide extinguisher operational features, colour and finish and anchorage details.

4.1.4 Submittals for Information

- A. Section 01300 - Submittals: Procedures for submittals.
- B. Manufacturer's Installation Instructions: Indicate special criteria and wall opening coordination requirements.