

Table 404.01 (1): Maximum VOC Content Limit Values for Paints and Coatings

Product Sub-Category	Type**	VOC (g/l)*
Interior matt walls and ceilings (Gloss <25 @ 60°)	WB	30
	SB	30
Interior glossy walls and ceilings (Gloss >25 @ 60°)	WB	100
	SB	100
Exterior walls of mineral substrate	WB	40
	SB	430
Interior/Exterior trim and cladding paints for wood and metal	WB	130
	SB	300
Interior/Exterior trim varnishes and wood stains, including opaque wood stains	WB	130
	SB	400
Interior/Exterior minimal build wood stains	WB	130
	SB	700
Primers	WB	30
	SB	350
Binding primers	WB	30
	SB	750
One-pack performance coatings	WB	140
	SB	500
Two-pack reactive performance coatings for specific end use such as floors	WB	140
	SB	500
Multi-colored coatings	WB	100
	SB	100
Decorative effect coatings	WB	200
	SB	200

* Ready to use

** WB- Water Based SB-Solvent Based

COMPLIANCE DOCUMENTATION

Table 404.01(2): Documents Required

Project Stages	Submittal Documents
Design Permit Application	1. DM BLDG Al Sa'fat declaration.
Construction Completion Application	1. DCL certificate. 2. Purchase order/delivery notes as a proof of purchase.
After Completion	Not applicable

REFERENCES AND ADDITIONAL INFORMATION

Dubai Municipality. (2015). Standard DMS 20:2015—Specification for Paints and Varnishes

Dubai Central Laboratory. (2018). Specific Rules for FA Certification of Low Emitting Materials as per Al Sa'fat Dubai Green Building System.