

Electrical sub-metering	The installation of separate meters to allow the measurement of electricity used in specific areas or individual items of equipment.
Electronic ballast	A piece of equipment required to control the starting and operating voltages of fluorescent lights. Electronic lighting ballasts use solid state circuitry and can greatly reduce or eliminate any flicker in the lamps.
Enabled access	Project design that incorporates accessibility for disabled people to and within a building.
Environmental tobacco smoke (ETS) (second hand smoke)	Airborne particles emitted from the burning of cigarettes, pipes, cigars, or shishas and from smoker's exhaled air.
Entrance lobby	Space immediately between the entrance-door and the interior of a building which acts as a transition area into the building.
Equivalent	Measure, standard, or reference material that has been deemed to be equal or better by Dubai Municipality.
Exhaust air	Air removed from a building space and discharged to the outside of the building through a mechanical or natural ventilation system.
Facilities operator	Party responsible for the maintenance and operation of a building or facility.
Fan systems	A system of fans used to supply or exhaust air from a building space.

