Components and Cladding		h ≤ 60 ft.
Figure 30.4-2B	**External Pressure Coefficients, GC_p**	**Gable/Hip Roofs 7°< θ ≤ 27°**
Enclosed, Partially Enclosed Buildings		

Notes:

1. Vertical scale denotes GC_p to be used with q_h.
2. Horizontal scale denotes effective wind area, in square feet (square meters).
3. Plus and minus signs signify pressures acting toward and away from the surfaces, respectively.
4. Each component shall be designed for maximum positive and negative pressures.
5. Values of GC_p for roof overhangs include pressure contributions from both upper and lower surfaces.
6. For hip roofs with $7° < θ ≤ 27°$, edge/ridge strips and pressure coefficients for ridges of gabled roofs shall apply on each hip.
7. For hip roofs with $θ ≤ 25°$, Zone 3 shall be treated as Zone 2.
8. Notation:
   - a: 10 percent of least horizontal dimension or 0.4h, whichever is smaller, but not less than either 4% of least horizontal dimension or 3 ft (0.9 m).
   - h: Mean roof height, in feet (meters), except that eave height shall be used for $θ ≤ 10°$.
   - $θ$: Angle of plane of roof from horizontal, in degrees.