

- 2.95 Flushing water shall be discharged via temporary discharge lines to the surrounding open desert area or into the existing storm water system or, if feasible, into road tankers. Discharge of flushing water into the existing storm water system shall be subject to the approval of the relevant Authorities.