1607.9 Reduction in live loads. Except for uniform live loads at roofs, all other minimum uniformly distributed live loads, L_0 , in Table 1607.1 are permitted to be reduced in accordance with Section 1607.9.1 or 1607.9.2. Roof uniform live loads, other than special purpose roofs of Section 1607.11.2.2, are permitted to be reduced in accordance with Section 1607.11.2. Roof uniform live loads of special purpose roofs are permitted to be reduced in accordance with Section 1607.9.1 or 1607.9.2.

Exception: Buildings not over two stories in height.

1607.9.1 General. Subject to the limitations of Sections 1607.9.1.1 through 1607.9.1.4, members for which a value of $K_{LL}A_T$ is 400 square feet (37.16 m²) or more are permitted to be designed for a reduced live load in accordance with the following equation:

$$L = L_o \left(0.25 + \frac{15}{\sqrt{K_{IL} A_T}} \right)$$
 (Equation 16-22)

For SI:
$$L = L_o \left(0.25 + \frac{4.57}{\sqrt{K_{LL}A_T}} \right)$$

where:

L = Reduced design live load per square foot (square meter) of area supported by the member.

 $L_{\rm o}$ = Unreduced design live load per square foot (square meter) of area supported by the member (see Table 1607.1).

 K_{LL} = Live load element factor (see Table 1607.9.1).

 $A_{\rm T}$ = Tributary area, in square feet (square meters).

L shall not be less than 0.50 L_0 for members supporting one floor and L shall not be less than 0.40 L_0 for members supporting two or more floors.

TABLE 1607.9.1 LIVE LOAD ELEMENT FACTOR, K_{LL}