

- C. The Work of this Section shall be completely co-ordinated with the work of other sections. Verify dimensions and Work of other trades which adjoin materials of this Section before the installation of items herein.

### **2.1.11 Protection**

A. Protection During Progress of Work:

1. When the ambient air temperature is more than 30°C in the shade and the relative humidity is less than 50% protect the masonry from direct exposure to the wind and sun for 48 hours after installation.
2. Protect partially completed unit masonry walls against weather when work is not in progress, by covering top of walls with strong, waterproof, non-staining membrane. Extend membrane at least 600 mm down both sides of walls and anchor securely in place ensuring that there is free air flow sufficient to prevent heat build-up.

B. Protection of Completed Work:

1. Keep completed walls clean and protect from staining. Use suitable corner guards to protect the corners of exposed masonry walls.

### **2.1.12 Extra Materials**

- A. Submit under provisions of Section 01700
- B. Provide 50 units of each size, colour and type of glazed pre-faced non-slip wall and floor ceramic tiles.

## **2.2 Part 2 Products**

### **2.2.1 Manufacturers - Concrete Masonry Units**

- A. See Supplementary Conditions in Volume 1

### **2.2.2 Concrete Masonry Units**

- A. Provide load bearing or non load bearing blocks as shown, complying with type classifications, weights, grades and curing requirements as hereinafter specified and the following general requirements:-
1. Do not use blocks which have chips, cracks, voids, streaks, iron spots or other substances which might stain exposed finished surfaces.
  2. Obtain blocks from one manufacturer, cured by one process and of uniform texture and colour, for each type required, for each continuous area and visually related areas.