

Table 5.3 — General areas inside buildings – Control rooms

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.3.1	Plant rooms, switch gear rooms	200	25	0,40	60	
5.3.2	Telex, post room, switchboard	500	19	0,60	80	

Table 5.4 — General areas inside buildings – Store rooms, cold stores

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.4.1	Store and stockrooms	100	25	0,40	60	200 lx if continuously occupied.
5.4.2	Dispatch packing handling areas	300	25	0,60	60	

Table 5.5 — General areas inside buildings – Storage rack areas

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.5.1	Gangways: unmanned	20	-	0,40	40	Illuminance at floor level.
5.5.2	Gangways: manned	150	22	0,40	60	Illuminance at floor level.
5.5.3	Control stations	150	22	0,60	80	
5.5.4	Storage rack face	200	-	0,40	60	Vertical illuminance, portable lighting may be used.

Table 5.6 — Industrial activities and crafts – Agriculture

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.6.1	Loading and operating of goods, handling equipment and machinery	200	25	0,40	80	
5.6.2	Buildings for livestock	50	-	0,40	40	
5.6.3	Sick animal pens; calving stalls	200	25	0,60	80	
5.6.4	Feed preparation; dairy; utensil washing	200	25	0,60	60	