

Doors, Windows, Switches and Glass Surfaces			
Facility/Building.....			Sheet Number
Space/Floor			
	YES	N/A	NON
			Observations

Windows

Without projections ≤ 2200 mm into the pedestrian area				
Opening mechanisms not require wrist turning				
Glazing at minimum of 900 mm height				
With guardrails if window opening < 1200 mm				

Switches

Located between 900 – 1200 mm height and located ≥ 600 mm from any corner				
Switch plates with contrast of 30 LRV against its background				
Switches can be activated with the elbow				

Glass surfaces

Presence of two horizontal bands of 100 mm high with contrast of 50 LRV				
First horizontal band height between 1400 – 1600 mm				
Second horizontal band height between 850 – 1000 mm				