

### A.1.3 Appendix2- Table 4

Appendix-2-Table-4-Telecom Room Size-For Mobile Services (IBS)

Number of Floors	Mobile service room size in meter (LXBXH)	Roof-Top room Size in Meeter (LXBXH)
Up to G + 10	Not Applicable	3m X 3m X 3m
G + 11 to G + 100	3m X 3m X 3m (Every 10 floors starting fro the besement level /Ground floor)	3m X 3m X 3m
Shopping malls and Bulk services building	Will be advised at NOC Stage	Will be advised at NOC Stage
Cluster of buildings with each having more than G + 5 floors	Will be advised at NOC Stage	Will be advised at NOC Stage

### 7.1.2 Appendix- 3 - du and ETC Telecom room label

Appendix-3- du and ETC Telecom room Label

