



Figure 14. Transversal section of a ramp

5.7.2. Landings

Landings shall fulfil the following requirements:

1. There are level landings required at the beginning and at the end of every ramp run. These landings shall have a minimum surface of 1500 mm x 1500 mm.
2. Landings should be level with less than 2% slope in the course of travel and crosswise directions.
3. Corridors located in landings shall have no less than 1200 mm width.
4. Doors shall be located at least 1500 mm away from the start or end of each ramp run.