

Level changes				
Facility/Building.....				Sheet Number
Space/Floor				
	YES	N/A	NON	Observations
Ramps				
Corridors in landings with no less than 1200 mm width				
Doors at ≥ 1500 mm from start of each ramp run				
Stairs				
With an alternative elevator				
Steps rises between 150 - 176 mm				
Steps stair treads between 300 - 340 mm				
Steps rise (R) and Treat (T) fulfil: $650 \text{ mm} < 2R + T < 700 \text{ mm}$				
No open risers or discontinued treads				
Steps with nosing ≤ 25 mm				
30 mm from the step edge shall present a reflectance contrast of 30 LRV				
Steps with same height with a ± 4 mm tolerance				
Stair flights steps number between 3 and 12				
Usable width ≥ 1200 mm				
Illumination at top and bottom $\geq 200\text{lux}$				