

Table 4-2 continued

**Notes:**

- <sup>1</sup> The figures shown are based upon 1 fixture being the minimum required for the number of persons indicated or any fraction thereof.
- <sup>2</sup> Building categories not shown on this table shall be considered separately by the Authority Having Jurisdiction.
- <sup>3</sup> Drinking fountains shall not be installed in toilet rooms.
- <sup>4</sup> Laundry trays. 1 laundry tray or 1 automatic washer standpipe for each dwelling unit or 1 laundry tray or 1 automatic washer standpipe, or combination thereof, for each 12 apartments. Kitchen sinks, 1 for each dwelling or apartment unit.
- <sup>5</sup> For each urinal added in excess of the minimum required, one water closet may be deducted. The number of water closets shall not be reduced to less than 2/3 of the minimum requirement.
- <sup>6</sup> As required by PSAI Z4.1, *Sanitation in Places of Employment* or equivalent International Standard(s) approved by the Authority Having Jurisdiction.
- <sup>7</sup> Where there is exposure to skin contamination with poisonous, infectious, or irritating materials, provide 1 lavatory for each 5 persons.
- <sup>8</sup> 60cm (2 ft.) of wash sink or 45cm (18 in.) of a circular basin, when provided with water outlets for such space, shall be considered equivalent to 1 lavatory.
- <sup>9</sup> Laundry trays, 1 for each 50 persons. Service sinks, 1 for each 100 persons.
- <sup>10</sup> General. In applying this schedule of facilities, consideration shall be given to the accessibility of the fixtures. Conformity purely on a numerical basis may not result in an installation suited to the needs of the individual establishment. For example, schools should be provided with toilet facilities on each floor having classrooms.
  - a. Surrounding materials, wall, and floor space to a point 60cm (2 ft.) in front of urinal lip and 1.2m (4 ft.) above the floor, and not less than 60cm (2 ft.) to each side of the urinal shall be lined with non-absorbent materials.
  - b. Trough urinals shall be prohibited.
- <sup>11</sup> A restaurant is defined as a business that sells food to be consumed on the premises.
  - a. The number of occupants for a drive-in restaurant shall be considered as equal to the number of parking stalls.
  - b. Hand-washing facilities shall be available in the kitchen for employees.
- <sup>12</sup> Where food is consumed indoors, water stations may be substituted for drinking fountains. Offices, or public buildings for use by more than 6 persons shall have 1 drinking fountain for the first 150 persons and 1 additional fountain for each 300 persons thereafter.
- <sup>13</sup> There shall be not less than 1 drinking fountain per occupied floor in schools, theatres, auditoriums, dormitories, offices, or public buildings.
- <sup>14</sup> The total number of water closets for females shall be at least equal to the total number of water closets and urinals required for males. This requirement shall not apply to Retail or Wholesale Stores.
- <sup>15</sup> For smaller-type Public and Professional Offices such as banks, dental offices, law offices, real estate offices, architectural offices, engineering offices, and similar uses. A public area in these offices shall use the requirements for Retail or Wholesale Stores.
- <sup>16</sup> Recreation or community room in multiple dwellings or apartment buildings, regardless of their occupant load, shall be permitted to have separate single-accommodation facilities in common-use areas within tracts or multi-family residential occupancies where the use of these areas is limited exclusively to owners, residents, and their guests. Examples are community recreation or multi-purpose areas in apartments, condos, townhouses, or tracts.
- <sup>17</sup> A drinking fountain shall not be required in occupancies of 30 or less. When a drinking fountain is not required, then footnotes 3, 12, and 13 are not applicable.
- <sup>18</sup> European water closets shall be permitted.

SI: 1cm = 0.39 in., 1m = 3.3 ft.