

**TABLE 1028.6.2 WIDTH OF AISLES FOR SMOKE-PROTECTED ASSEMBLY**

<b>TOTAL NUMBER OF SEATS IN THE SMOKE-PROTECTED ASSEMBLY OCCUPANCY</b>	<b>INCHES OF CLEAR PER SEAT SERVED</b>			
	<b>Stairs and aisle steps with handrails within 30 inches</b>	<b>Stairs and aisle steps without handrails within 30 inches</b>	<b>Passageways, doorways and ramps not steeper than 1 in 10 in slope</b>	<b>Ramps steeper than 1 in 10 in slope</b>
Equal to or less than 5,000	0.200	0.250	0.150	0.165
10,000	0.130	0.163	0.100	0.110
15,000	0.096	0.120	0.070	0.077
20,000	0.076	0.095	0.056	0.062
Equal to or greater than 25,000	0.060	0.075	0.044	0.048

For SI: 1 inch = 25.4 mm.