

**PROJECT:****CLIENT : DMAT****CONSULTANT :****ITEM DESCRIPTION: -MOTOR CONTROL CENTER & DISTRIBUTION BOARDS****TEST PROCEDURE:**

SL.NO	CHECK TO BE PERFORMED WHERE APPLICABLE	RESULT	REMARKS
<b>(A) VISUAL INSPECTION</b>			
1	GENERAL		
	a. Enclosure frame and covers		
	b. Internal supports and bracket		
	c. Doors and locks		
	d. Ventilation louvers and fans		
2	FINISH		
	a. External color		
	b. Internal color		
	c. Alignment of instrument bezels on the door		
3	Defective materials (if any)		
4	BUSBAR Tightness of bus bar joints using torque wrench if any connection in feeder terminals		
5	POWER AND CONTROL OUTGOING CABLES		
	a. Connections as per the approved drawings		
	b. Tightness of the connection in feeder terminals		
6	EARTHING		
	a. Panel frame		
	b. Signal screens		
	c. Cable armor		