

Level changes				
Facility/Building.....				Sheet Number .....
Space/Floor .....				
	YES	N/A	NON	Observations
Stairs				
Landing with same width of stair and a length $\geq 1200$ mm				
Empty space with height $< 2200$ mm under the stair is protected				
Handrails				
300 mm horizontal extension at its ends				
Presence of intermediate handrail for stairs larger than 2400 mm				
Height of 900 mm				
Additional handrail at a height between 650 - 750 mm				
Circular section of 30 - 40 mm separated from the wall $\geq 40$ mm				
Contrast of 30 LRV against its background				
Elevators				
Present in buildings with more than one floor				
<b>Dimensions shall comply:</b> One door - 1200 x 1500 mm Two opposing doors - 1200 x 1500 mm Two doors in 90° - 1500 x 1500 mm				
Automatic doors with a width of 900 mm and colour contrast against walls				