

6 Retesting required.

- B. Assemble background documentation for dispute and claim settlement by Engineer and Department.

7.1.5 Mains Electricity & Liaison with ADWEA

Electrical Maintenance Engineer shall:

- A. Be acquainted with ADWEA regulations and requirements.
- B. Liaise with ADWEA to determine the power supply required and all other pertinent information, as required, and make all necessary arrangements for its connection.
- C. Arrange through written request for ADWEA to undertake the testing and inspection necessary in order that the electricity supplies may be connected when required. Bear the costs of this.

7.1.6 Equipment Start-Up

Maintenance Engineer shall:

- A. Verify utilities, connections, and controls are complete and equipment is in operable condition as required by Specification
- B. Observe start-up and adjustments, test run, record time and date of start-up, and results.
- C. Observe equipment demonstrations to DMAT; record times and additional information required for operation and maintenance manuals.

7.1.7 Inspection and Acceptance of Equipment

Maintenance Engineer shall:

- A. Prior to inspection, verify that equipment is tested, operational, clean, and ready for operation.
- B. Assist Engineer with review. Prepare list of items to be completed and corrected.

7.2 Part 2 Products

Not Used.