

Window Contact:

When balcony door or window is opened, this activates the door / window contact which is wired to GRMS controller. After a predefined time delay, the controller would turn off the air conditioning unit.

This regulation only applies to guest rooms; all other areas of the hotel must meet the requirements of *Regulations 502.06: Lighting Controls* and *502.08: Control Systems for HVAC Systems*.

COMPLIANCE DOCUMENTATION

Table 502.09(1): Documents Required

Project Stages	Submittal Documents
Design Permit Application	1. DM BLDG Al Sa'fat declaration.
Construction Completion Application	1. Control schematic and sequence of operation 2. Functional test to verify the controls and sequence of operation.
After Completion	1. Performance and commissioning report.

REFERENCES AND ADDITIONAL INFORMATION

American Society of Heating, Refrigerating and Air-Conditioning Engineers. (2016). ASHRAE standard 90.1: Energy Standard for Buildings Except Low-Rise Residential Buildings, Section 6.4.3.3.5 Automatic Control of HVAC in Hotel/Motel Guest Rooms and Section 9.4.1.3: Special Application: Guestrooms.