



Regulations of Construction Conditions And Specifications in the Emirate of Sharjah

hyliogitats may be drained if their density exceeds 10mg/liter in the used water.

17. Any dangerous materials may not be drained into the sewerage pipes if their density exceeded what has been stated in the following table:

Iron and Manganese	(Together)	5mg/L
Chrome		1mg/L
Copper		2mg/L
Cyanide		1mg/L
Zinc		3mg/L
Nickel		2mg/L