

Toilets and Ablution Areas				
Facility/Building.....				Sheet Number
Space/Floor.....				
	YES	N/A	NON	Observations
Showers				
Shower floor surface flush				
Water evacuation slope $\leq 4\%$				
Dimensions at least 865 x 1200 mm and a seat of at least 400 x 400 mm				
Seat located at a height between 450 - 500 mm and separated from the wall between 150 - 200 mm				
Horizontal bar length 800 mm and height of 700 - 750 mm				
Vertical bar length of 800 mm in the lateral wall of the shower seat at a height of 800 mm				
Distance between seat bars between 670 - 700 mm				
Family toilets				
1 family toilet within 300 m distance from any part of the building				
Full family toilets				
With a folding adult changing board				
Second sink at a height of 500 mm				
Manoeuvring turning space of at least 2000 mm				
With a urinal with usable height of 400 mm				