

Toilets and Ablution Areas				
Facility/Building.....				Sheet Number .....
Space/Floor.....	YES	N/A	NON	Observations
Accessible toilets				
Door with horizontal 300 mm grab bar placed between 900 - 1000 mm at 300 mm from the hinge side				
Latch operable with the elbow installed between 900 - 1200 mm				
Coat hanger between 1100 - 1400 mm				
Grab bars in accessible toilets				
Separation from the wall $\geq 45$ mm				
Withstand a force of 1 kN in any direction				
Circular diameter between 30 - 40 mm				
Horizontal bars height between 700 - 750 mm. Support length of 700 mm				
Bars mounted in the transfer space must be foldable				
With two transfer areas, distance between both grab bars 670 mm and 700 mm				
With one transfer area, horizontal bars mounted in wall 300 mm from the sanitary edge				
With vertical bar				
Toilet height between 450 - 500 mm				