

If IAQ test report demonstrates that maximum concentrations of contaminants have exceeded, additional flush-out procedures with outside air should be implemented. Test must be conducted again until it can be verified that contaminant levels are within the acceptable range.

## COMPLIANCE DOCUMENTATION

**Table 401.07(4): Documents Required**

Project Stages	Documents Required
Design Permit Application	1. DM BLDG Al Sa'fat declaration.
Construction Completion Application	Not applicable
After Completion	Not applicable

## REFERENCES AND ADDITIONAL INFORMATION

Government of Dubai. (2003). Local Order No. 11 (law 53, 54 and 55) and Administrative Resolution (Law 61,62 and 63).

International Organization for Standardization. (2014). ISO 16000-01, Part 1: General aspects of sampling strategy.

ASTM International (2018). ASTM D8068 - 18, Standard Practice for Collection of Culturable Airborne Fungi or Bacteria on Agar Plates by Inertial Impaction Systems.