

<p>poured to <math>\frac{1}{8}</math>" thickness above top of corrugations of <math>1\frac{5}{16}</math>"-deep galvanized steel deck maximum span 8'-0" for 0.024" (No. 24 galvanized sheet gage) or 6'-0" for 0.019" (No. 26 galvanized sheet gage) with deck supported by individually protected steel framing.</p> <p>Approved polystyrene foam plastic insulation board having a flame spread not exceeding 75 (1" to 4" thickness) with vent holes that approximate 3 percent of the board surface area placed on top of perlite slurry. A 2' by 4' insulation board contains six <math>2\frac{3}{4}</math>" diameter holes. Board covered with <math>2\frac{1}{4}</math>" minimum perlite concrete slab.</p>										
--	--	--	--	--	--	--	--	--	--	--

*(continued)*