

Table 5.29 — Places of public assembly – Restaurants and hotels

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
5.29.1	Reception/cashier desk, porters desk	300	22	0,60	80	
5.29.2	Kitchen	500	22	0,60	80	There should be a transition zone between kitchen and restaurant.
5.29.3	Restaurant, dining room, function room	-	-	-	80	The lighting should be designed to create the appropriate atmosphere.
5.29.4	Self-service restaurant	200	22	0,40	80	
5.29.5	Buffet	300	22	0,60	80	
5.29.6	Conference rooms	500	19	0,60	80	Lighting should be controllable.
5.29.7	Corridors	100	25	0,40	80	During night-time lower levels are acceptable.

Table 5.30 — Places of public assembly – Theatres, concert halls, cinemas, places for entertainment

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
5.30.1	Practice rooms	300	22	0,60	80	
5.30.2	Dressing rooms	300	22	0,60	90	Lighting at mirrors for make-up shall be "glare-free". Disability glare should be avoided at mirrors for make-up.
5.30.3	Seating areas – maintenance, cleaning	200	22	0,50	80	Illuminance at floor level.
5.30.4	Stage area - rigging	300	25	0,40	80	Illuminance at floor level.

Table 5.31 — Places of public assembly – Trade fairs, exhibition halls

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
5.31.1	General lighting	300	22	0,40	80	