

C3 - Opportunistic visual inspection

D5 - Not known

Confidence Factors – Internal Condition (Per Pip/SewerLength)

Reference

Source

A1 - Verified pipe sample survey
- Verified by CCTV survey
- New Installation

A2 - Opportunistic site data collection
- Fibre optic survey

A3 - Extrapolated from asset/ pipe sampling survey or opportunistic data to immediate surrounding network of sample material

C4 - Estimated from information generally available on the network.

D5 - Not known

Confidence Factors - Material (Per Pipe/Sewer Length)

Reference

Source

A1 - As Constructed drawing
- Verified asset survey (pipe sampling)
- Opportunistic site data collection.

A2 - Verified standard survey
- As stated on record drawing certified up to date and correct by an operational supervisor.

B3 - Extrapolated from 1 and 2 type data to surrounding network for continuity of record
- As detailed on mains record drawings not certified up to date.

B4 - Where no data exists, unconfirmed verbal reports from operational supervisor.

D5 - Where no data exists, assumed for continuity of network
- Estimated from materials used in the area