

- C. Manufacturer's Certificate: Certify that Products meet or exceed specified requirements.

4.1.5 Submittals at Project Close-Out

- A. Section 01700 - Contract Closeout: 01730 - Operation and Maintenance Data: Procedures for submittals.
- B. Maintenance Data: Include test, refill or recharge schedules and re-certification requirements.

4.1.6 Environmental Requirements

- A. Do not install extinguishers when ambient temperature may cause freezing of extinguisher ingredients.

4.2 Part 2 Products

4.2.1 Extinguishers

- A. Not Used
- B. Dry Chemical Type: Cast steel tank, with pressure gage; Size and classification as scheduled.
- C. Not Used
- D. Carbon Dioxide Type: Cast steel tank, with pressure gage; size and classification as scheduled.
- E. Halogenated Type: Stainless steel or Cast steel tank, with pressure gage; size and classification as scheduled.
- F. Extinguisher Finish: Stainless steel, polished chrome, enamel. Colour as selected.

4.2.2 Fire Extinguisher Cabinets

- A. Metal: Formed sheet steel, 0.9 mm thick base metal.
- B. Configuration: Recessed type, sized to accommodate accessories, dimensions of 400 mm wide x 750 mm high x 250 mm deep.
- C. Not Used
- D. Door: 0.9 mm thick, reinforced for flatness and rigidity; recessed handle in stainless steel escutcheon and cylinder lock with latch.
- E. Door Glazing: Glass, clear, 3 mm thick tempered.