

- Risk management Plan for management responsibilities, training and competence;
- An Exposure Risk Prevention or Control Plan;
- Record Keeping Plan; and
- Responsibility Plan for manufacturers, importers, suppliers and installers.

A 'water system' or 'water based system' includes all plant/equipment and components associated with that system e.g. All associated pipework, pumps, feed tanks, valves, showers, heat exchangers, quench tanks, chillers etc. The system must be considered as a whole and not as isolated parts/components. Dead legs and parts of the system used intermittently must be included as part of the system.

References

- HSE (2013) *Legionnaire's Disease - The Control of Legionella Bacteria in Water Systems, Approved Code of Practice and Guidance (ACoP)*, L8. UK.
 - HSE (2003) *Control of Legionella bacteria in water systems: Audit Checklists*. UK.
 - EHSMS (2012) *EHS RI - CoP 12.0 - Prevention and Control of Legionnaires Disease*. Abu Dhabi, UAE.
-