

<b>2. DMAT</b>					Form No. :
<b>Site Precast Concrete Yard Check List:</b>					
<b>Contractor:</b>		<b>ADSS Contract No.</b>		<b>Location:</b>	
				<b>Inspection Date:</b>	
<b>Sl. No.</b>	<b>Requirement</b>	<b>Compliance</b>			<b>Comments</b>
		<b>Yes</b>	<b>NO</b>	<b>N/A</b>	<b>( Obtain details where applicable )</b>
3.	The yard boundary wall shall be having protection from wind-blown sand.				
4.	The area of the yard shall be of sufficient size to accommodate the following facilities, <ul style="list-style-type: none"> <li>• Rebar fabrication</li> <li>• Casting area</li> <li>• Curing area</li> <li>• Storage area</li> <li>• Coating area</li> </ul>				
5.	Access gates shall be facilitated at suitable locations				
6.	The yard shall have elevated concrete or asphalt paved flooring.				
7.	Covered roofing area shall be provided for green concrete sampling zones.				
8.	Water points shall be provided at convenient locations with easy regulating valves and flexible hosepipes.				
9.	The yard shall be adequately illuminated and provided with overhead floodlights.				
10.	Adequate lifting and transportation equipment shall be facilitated.				