

Table 5.42 — Health care premises – Ear Examination rooms

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.42.1	General lighting	500	19	0,60	90	
5.42.2	Ear examination	1 000	-	-	90	

Table 5.43 — Health care premises – Scanner rooms

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.43.1	General lighting	300	19	0,60	80	
5.43.2	Scanners with image enhancers and television systems	50	19	-	80	DSE-work, see 4.9.

Table 5.44 — Health care premises – Delivery rooms

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.44.1	General lighting	300	19	0,60	80	
5.44.2	Examination and treatment	1 000	19	0,70	80	

Table 5.45 — Health care premises – Treatment rooms (general)

Ref. no.	Type of area, task or activity	E_m lx	UGR_L –	U_o –	R_a –	Specific requirements
5.45.1	Dialysis	500	19	0,60	80	Lighting should be controllable.
5.45.2	Dermatology	500	19	0,60	90	
5.45.3	Endoscopy rooms	300	19	0,60	80	
5.45.4	Plaster rooms	500	19	0,60	80	
5.45.5	Medical baths	300	19	0,60	80	
5.45.6	Massage and radiotherapy	300	19	0,60	80	