

| Toilets and Ablution Areas | | | | |
|--|-----|-----|-----|--------------------|
| Facility/Building..... | | | | Sheet Number |
| Space/Floor..... | | | | |
| | YES | N/A | NON | Observations |
| Flushing systems are operated by pressure or with a flush handle | | | | |
| Faucets shall be operated by pressure with a lever handle or with a sensor | | | | |
| Distance to the faucet shall be less than 600 mm and vertical between 700 mm and 1200 mm. | | | | |
| Lower edge of mirror 900 mm height | | | | |
| Accessible toilets | | | | |
| 1 accessible toilet for each gender in every floor or 1 independent accessible toilet for both genders | | | | |
| 1 accessible toilet within a 150 m distance from any part of the building | | | | |
| Corridors width in toilets, showers, lockers spaces of 1200 m | | | | |
| Manoeuvring turning space diameter of 1500 mm in circulations | | | | |
| Manoeuvring space diameter of 1500 mm inside the toilet | | | | |
| Lateral interaction space on both sides of the toilet or on one side if symmetrical units | | | | |
| Door open outwards or is sliding | | | | |