Wayfinding						
Facility/Building						Sheet Number
Space/Floor						Oncer Number
			YES	A/N	NON	Observations
Font size according to reading distance:						
Reading distance	Minimum size	Recommended size				
≥50 meters	170 mm	200 mm				
20 meters	140 mm	180 mm				
5 meters	70 mm	140 mm				
4 meters	56 mm	110 mm				
3 meters	42 mm	84 mm				
2 meters	28 mm	56 mm				
1 meter	14 mm	28 mm				
0.5 meters	7 mm	14 mm				
Signs out of the accessible path and clear headroom ≥ 2200 mm						
Two of the three channels of communication: acoustic, visual and tactile						
Guiding tactile pavements in:						
- Open squares without defined walking paths						
- Metro, tramway and ferry networks						
- From building entrance to information desk or reception in administration buildings						