



**Article (2/54): Lifts**

1. One lift at least must be provided and to be fit for use by the disabled persons in the common buildings.
2. The lift door width must not be less than 80cm with suitable space for accommodating the wheelchair, and to be equipped with side knobs, along with studying the height of keyboard, the period of opening and closing the door, and providing it with the light and sound instructions for use by deaf or blind persons.

**Article (2/55): Water Closets**

1. One water closet at least must be provided in the common buildings that meet the conditions of use by the disabled persons.
2. The door width must not be less than 75cm, and the door must open outward, with the possibility of being opened from outside in emergency cases.
3. The space of water closet must allow the movement and rotation of wheelchair easy.
4. Water closet must be provided with suitable sanitary devices, along with selecting and installing the necessary fittings like taps, knobs and mirrors, which must be handy to the disabled using wheelchair.