

Bus shelters and signpost

Facility/Building

Space/Floor

Sheet Number

	YES	N/A	NON	Observations
Not invading accessible path				
With a free of obstacles path in one of the sides ≥ 1200 mm				
Manoeuvring ≥ 1500 mm diameter inside the shelter				
Height ≥ 2200 mm				
No obstacles between shelter and access to bus				
Glazed walls with marks				
With fixed bench				
With standing support of height between 700 - 750 mm and separated 200 mm from wall				
Average illumination 20 lux and ≥ 50 lux at boarding time				
Boarding area with tactile warning surface				

Bus signpost

Above 2200 mm without protruding				
Bus information height between 1200 - 1600 mm				
Bus line identification number with letter height ≥ 140 mm				