

**Appendix 1****1. DMAT**

Form No:

**Commercial precast concrete yard check list:**

<b>Precast concrete yard name:</b>		<b>Location:</b>			<b>Inspection date:</b>
<b>SI No.</b>	<b>Requirement</b>	<b>Compliance</b>			<b>Comments ( Obtain details where applicable )</b>
		<b>Yes</b>	<b>No</b>	<b>N/A</b>	
4.	For Fusion Bond Epoxy coated (FBEC) rebars, <ul style="list-style-type: none"> <li>• Teflon mandrels shall be used of sufficient diameters as per relevant standard.</li> <li>• Approved touch-up epoxy material shall be available.</li> <li>• Plastic coated tie-wire shall be used.</li> </ul>				
<b>E</b>	<b>Coating Area</b>				
1.	The yard shall be fully covered, enclosed and properly ventilated.				
2.	The yard shall be equipped with the suitable equipment for surface preparation, mixing and application in accordance with the coating manufacturer recommendations.				