

5.5 Water metering

Related Credits: PW-R2: Water Monitoring

Water metering

PW-R2 requires easily accessible and clearly labelled water meters to be provided and capable of monitoring all exterior water consumption. The following must be separately sub-metered where present:

- Irrigation Systems
- Heat Rejection
- Swimming Pools
- Water Features

The meters are also required to have data logging capability and be connected to a central monitoring system so that the exterior water consumption may be recorded. This, and a better understanding of both interior and exterior water use will help determine areas of high water consumption, identify leaks quickly, and pursue opportunities to save water.

Example 5.5: Diagram of water monitoring

