

- E. The Contractor shall undertake a deflection survey of the existing pipelines before commencing any dewatering works when excavation is to be undertaken within 10 metres of an existing pipeline:
 - 1. Measure vertical and horizontal pipe deflections at two-metre intervals and at each side of a joint.
- F. The Contractor shall repeat the deflection survey on completion of the work and removal of the dewatering installation.
- G. The Contractor shall reinstate existing pipeline where method of working causes a change in the deflection of the existing pipeline or adversely affects the sewer in any way. The maximum deflection of the reinstated pipe is 3 per cent.

21.1.20 Removal of Temporary Conduits

- A. The Contractor shall remove discharge pipelines and dewatering ports immediately on completion of dewatering.

21.2 Part 2 Products

Not Used.

21.3 Part 3 Execution

Not Used.

END OF SECTION