

Table 5.32 — Places of public assembly – Museums

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
5.32.1	Exhibits, insensitive to light					Lighting is determined by the display requirements.
5.32.2	Exhibits sensitive to light					1. Lighting is determined by the display requirements. 2. Protection against damaging radiation is paramount.

Table 5.33 — Places of public assembly – Libraries

Ref. no.	Type of area, task or activity	$E_m$ lx	$UGR_L$ —	$U_o$ —	$R_a$ —	Specific requirements
5.33.1	Bookshelves	200	19	0,40	80	
5.33.2	Reading area	500	19	0,60	80	
5.33.3	Counters	500	19	0,60	80	