

2905. Condensate disposal collection. Condensate from all cooling coils and evaporators shall be conveyed from the drain pan outlet to an *approved* place of disposal and collected for onsite reuse. Fire sprinkler test water from the main test drain shall be collected for on-site reuse. Piping for these systems shall maintain a minimum horizontal slope in the direction of discharge of not less than one-eighth unit vertical in 12 units horizontal (1-percent slope).
Collected water shall be stored in an approved collection reservoir and reused.